



Persidangan Jurutera-jurutera @PICC, Putrajaya 4 – 5 September 2013

Energy Efficiency - Sultan Salahuddin Abdul Aziz Shah (SSAAS) Building Modeling

zilaila@jkr.gov.my

Isi Kandungan

1. Latar Belakang
 - Kajian Penggunaan Tenaga
2. Analisis Penggunaan Tenaga
 - Bil Elektrik kWh
3. Methodologi Modeling Energy Efficiency - Experimental Setup
4. Hasil Kajian



1. Latar Belakang




Kajian Penggunaan Tenaga Di Bangunan SSAAS



Bangunan Sultan Salahuddin Abdul Aziz Shah adalah antara mercu tanda terawal yang dibina dimana lokasinya terletak di Bukit SUK, Seksyen 5, Shah Alam.

Dibina pada 2hb Feb 1982 serta siap sepenuhnya 1984 dan telah dirasmikan oleh Sultan Salahuddin Abd Aziz Shah pada 2hb Feb 1985.

Bangunan setinggi 24 tingkat ini dibina berkonsepkan Kapal Kargo tradisional Bugis, menempatkan Pejabat Setiausaha Kerajaan serta jabatan-jabatan Kerajaan Negeri Selangor.



Kajian Penggunaan Tenaga Di Bangunan SSAAS



Airconditioning Mechanical Ventilation (ACMV) merupakan penggunaan tenaga terbesar seterusnya penyumbang tenaga bil elektrik tinggi

Kajian Penggunaan Tenaga Di Bangunan SSAAS

Penggunaan tenaga elektrik di Bangunan Sultan Salahuddin Abdul Aziz Shah (SSAAS) Shah Alam berdasarkan bil elektrik adalah kira-kira RM 400,000.00 sebulan.

BIL ELEKTRIK

**TENAGA
NASIONAL BERHAD** (200866-W)

STN.	NO. PLGN.	DS.	NO. KONT.	KOD CAS.	AMN. CAS.	NO. BIL	TARIK
1510	00092852	09	00085	0.00	14950485	025	

KETUA PEN. SETIAUSAHA (P)
TKT 18
BHG PENTADBIRAN
BGN S.U.K
SEK 5
40000 SHAH ALAM SELANGOR
SEJARAH

TARIKH
BIL TERAKHIR 01/04/2009
BYRN. TERAKHIR 23/04/2009

760
399,907.82
BAKI KEMASUKAN HINGGA: 01/05/2009
183

CAGARAN TAMBAHAN	MUATAN TERTINGGI DICATAT	REFERENCE KWH
0.00	4,716.00	1550357.14

BACAAN	NO. JANGKA	FA	BACAAN DAHULU	BACAAN SEMASA	PENGUNJUTAN	KW
M AC06000030	1.0000	0.00	1,071,183.00	1,071,183.00	0.00	0.00
M AC06000030	1.0000	0.00	4,285.00	4,285.00	0.00	0.00
M AC06000030	1.0000	0.00	317,502.00	317,502.00	0.00	0.00

C A J	UNIT	FAKSA	AMAI
PER	1,071,183.00	0.288	308,500.70
Consumption tar.Cl	4,285.00	23.930	102,540.05

TARIKH BACAAN DAHULU : 01/04/2009
JENIS: N SEMASA : 01/05/2009
NO. TELEFON
PEMASANGAN ROSAK : 15454
LAMPU JALAN ROSAK : 15454
PEJABAT : 03-55102020
NO TIANG :

UNTUK MENGELOKAN PEMOTONGAN BEKALAN
ELEKTRIK,
SILA BAYAR SEBELUM: 31/05/2009
DI: TNS Shah Alam

PSN DAMAI

CAP AKHIR PENERIMA WANG
40100 SHAH ALAM SELANGOR

**Bil April 2009
Jumlah Perlu Bayar
RM 11,882.25**

JUMLAH KESSEL
JUMLAH CAJ : 411,040.75
PELARANAN ANGGARAN : 0.00
PELARAN CAJ : 0.00
PEJABAT : 861.53
BIL SEMASA : 411,882.28
TUNGGAKAN : 0.00
CAGARAN TAMBAHAN : 0.00
JUMLAH : 411,882.27
PENGUNJUTAN : 0.00
JUMLAH PERLU DIBAYAR : 411,882.25

Bil April 2009
Jumlah Perlu Bayar
RM 411,882.25

BIL ELEKTRIK

TENAGA NASIONAL BERHAD (200866-W)

STN.	NO. PLGN.	DS.	NO. KONT.	KOD CAS.	AMN. CAS.	NO. BIL	TARIK
1510	00092552	09	00085020	E	0.00	16599207	025

KETUA PEN. SETIAUSAHA (P)

TKT 18

BHG PENTADBIRAN

BGN S.U.K

SEK 5

BIL. SALINAN

BIL LFC MUKA : 1

SEJARAH

TARIKH	AMAIIN	JENIS BACAAN: N	NO. BACAAN: 00001183
BIL TERAKHIR 01/04/2010	445,804.35	BAKI KEMASUKAN HINGGA: 30/04/2010	
BYRN. TERAKHIR 15/04/2010	445,804.39		

CAGARAN TAMBAHAN	0.00	TUNGGAKAN	0.04-
MUATAN TERTINGGI DICATAT	4,716.00	CMPC/PMPC	0.00
REFERENCE KWH	1550357.14		

BACAAN

NO. JANGKA	FJ	BACAAN DARULU	BACAAN SEMAGA	PENGUNAAN	KTRG
M AC06000030	1.0000	0.00	1,138,021.00	1,138,021.00	kwh
M AC06000030	1.0000	0.00	4,623.00	4,623.00	KW
M AC06000030	1.0000	0.00	441,404.00	441,404.00	KVA

C A J

PERKE	UNIT	NARGA	AMAIIN
Consumption tar.Cl	1,138,021.00	0.288	327,750.05
Consumption MD Cl	4,623.00	23.930	110,628.39

TARIKH BACAAN

JENIS: N	DARULU : 01/04/2010	JUMLAH KRCIL
NO. TELEFON	SEMAGA : 01/05/2010	JUMLAH CAJ : 438.37
PEMASANGAN ROSAK		PELAPASAN ANGGARAN : 1
LAMPU JALAN ROSAK		PELABAGI CAJ : 1
PEJABAT		PENALITI : 1
NO TIANG		BIL SEMAGA : 438.37
		TUNGGAKAN : 1
		CAGARAN TAMBAHAN : 1
		JUMLAH : 438.37
		PENGUNAAN : 1
		JUMLAH PERLU DIBAYAR : 438.37

UNTUK MENGELOKAN PEMOTONGAN BEKALAN ELEKTRIK,

SILA BAYAR SEBELUM: 31/05/2010

DI: TNB Shah Alam

PSN DAMAI



CAP AKHIR PENERIMA WANG
40100 SHAH ALAM SELANGOR

Bil April 2010
Jumlah Perlu Bayar
RM 438,378.40

JUMLAH KECIL	
JUMLAH CAJ	438,378.44
PELARASAN ANGGARAN	0.00
PELBAGAI CAJ	0.00
PENALTI	0.00
BIL SEMASA	438,378.44
TUNGGAKAN	0.04
CAGARAN TAMBAHAN	0.00
JUMLAH	438,378.40
PENGGENAPAN	0.00
JUMLAH PERLU DIBAYAR:	438,378.40

SISTEM INOVASI

Sistem Asal



Nota :

MSB: Main Switch Board

KW :Kawalan Motor

A/T:Autotransformer

M: Motor

C: Optimal Capacitor Placement

S/D: Star Delta

Sistem Inovasi

Kos Pemasangan :RM250,000.00

Pulangan Modal : 5 bulan

Mengurangkan arus permulaan
(Starting Current)

➤ Mengurangkan muatan tertinggi (MD)

➤ Seterusnya dapat mengurangkan
bil elektrik

➤ Memperbaiki dan mengekalkan Faktor
Kuasa

➤ Meningkatkan kecekapan tenaga
dengan mengurangkan kehilangan
kuasa





2. Analisis Penggunaan Tenaga



Analisis Bil Elektrik

ANALISA STATISTIK INISIATIF INOVASI

➤ Jadual Penggunaan Elektrik Bagi Tempoh April 2010 Hingga Mac 2011


BIL	TARIKH BIL	MUATAN TERTINGGI (MD)	CAJ MUATAN TERTINGGI (RM)	JUMLAH BAYARAN BIL (RM)
1	1 Apr-10	4,469.00	106,943.00	445,804.35
2	1 May-10	4,623.00	110,628.39	438,378.40
3	1 Jun-10	4,625.00	110,676.25	435,475.40
4	1 Jul-10	4,438.00	106,201.34	415,552.45
5	1 Aug-10	4,450.00	106,488.50	436,859.60
6	1 Sep-10	4,181.00	100,051.33	386,392.40
7	1 Oct-10	4,224.00	101,080.32	364,272.80
8	1 Nov-10	4,357.00	104,263.01	430,417.50
9	1 Dec-10	4,445.00	106,368.85	419,040.05
10	1 Jan-11	4,152.00	99,357.36	404,332.05
11	1 Feb-11	3,945.00	94,403.85	371,308.60
12	1 Mar-11	4,185.00	100,147.05	365,047.20

SEBELUM

SELEPAS

Statistik Inovasi

➤ Pengurangan Bayaran Bil Elektrik



Contoh Anggaran penjimatan dari penurunan MD

Perbezaan MD pada Mei 2010 dan Mac 2011 = 4,623 – 4,185 = 438 unit

Kadar caj MD/unit = RM 25.90 (tarif baru TNB)



Jumlah bayaran caj MD = 438 x RM25.90 = RM 11,344.2 (untuk sebulan)

Anggaran untuk setahun = RM 11,344.2 x 12 bulan

Anggaran penjimatan = RM 136,130.40

Bil elektrik TNB selepas kadar kenaikan tarif elektrik. 1 Jun 2011

BIL	TARIKH BIL	MUATAN TERTINGGI (MD)	CAJ MUATAN TERTINGGI (MD) (RM)	JUMLAH BAYARAN BIL (RM)
1	1 Apr-11	4,221.00	101,008.00	416,292.00
2	1 May-11	4,457.00	107,374.39	446,534.40
3	1 Jun-11	4,378.00	113,390.00	467,295.00
4.	1 Julai-11	3,980.00	103,082.00	480,022.22
5	1 Ogos-11	4,248.00	110,023.20	403,438.16
6	1 Sep-11	4,298.00	111,318.20	429,514.94
7	1 Okt-11	4,298.00	111,318.20	445,773.15
8	1 Nov-11	4,266.00	110,489.40	427,706.98
9	1 Dis-11	4,144.00	105,723.80	427,443.69
10	1 Jan-12	4,082.00	104,263.01	430,417.50
11	1 Feb -12	4,614.00	106,656.20	408,843.24
12	1 Mac-12	4,118.00	119,502.60	474,443.77
13	1 Apr -12	4,279.00	110,826.10	442,186.74
14	1 Mei-12	4,276.22	110,748.40	473,077.63
15	1 Jun-12	4,102.00	106,241.80	440,203.29
16	1 Julai-12	4,445.00	115,125.50	453,385.83
17	1 Aug-12	3,891.00	100,776.90	370,901.56



Penghargaan Johan Inovasi 2011



SETIAUSAHA KERAJAAN,
NEGERI SELANGOR DARUL EHSAN,
TINGKAT 19,
BANGUNAN SULTAN SALAHUDDIN ABDUL AZIZ SHAH,
40503 SHAH ALAM,
SELANGOR DARUL EHSAN.



Tel : 03-5514 2134 (Terus)
Fax : 03-5544 7042 (Am)
03-5510 3062

"KEJUJURAN DAN KETEKUNAN"

SELANGORSHINES

Dato' Ir. Abdullah bin Abd. Rahman
Pegawai Kerja Raya Negeri Selangor
Tingkat 1, Bangunan SSAAS,
40582 Shah Alam,
Selangor Darul Ehsan.

YBhg Dato',

SURAT PENGHARGAAN

2. Pentadbiran Kerajaan Negeri Selangor dengan ini mengucapkan setinggi-tinggi tahniah kepada Jabatan Kerja Raya Negeri Selangor di atas pengiktirafan dan anugerah yang diterima sepanjang Tahun 2011 seperti berikut:

- Johan Perbarisan Terbaik Kategori Jabatan Kerajaan
Sempena Majlis Sambutan Maulidur Rasul Peningkat Negeri Selangor
- Persijilan Amalan Persekitaran Berkualiti 5S
Ibu Pejabat JKR Negeri Selangor
- Persijilan Amalan Persekitaran Berkualiti 5S
Pejabat JKR Daerah Kuala Selangor
- Johan Anugerah Inovasi JKR Malaysia
Bahagian Elektrik, JKR Negeri Selangor

Tempat Ketiga
Anugerah Penyelenggaraan Jalan Terbaik JKR Malaysia
Pejabat JKR Daerah Kuala Selangor

Tempat Ketiga
Anugerah Pejabat JKR Daerah Terbaik JKR Malaysia
Pejabat JKR Daerah Hulu Selangor



NATIONAL SEMINAR

ON ASSETS AND PROJECTS MANAGEMENT



Menyertai Conference, Pameran dan Seminar



Pameran di Dewan Tan Sri Khalid Mahfuz 1 Nov 2012





WIF KL
WORLD INNOVATION FORUM
KUALA LUMPUR

3-7 NOVEMBER 2012

Kuala Lumpur Convention Centre
Malaysia

**INCLUSIVE INNOVATION
FOR TRANSFORMATION**



Pemacu Transformasi
TAMBAH LAIN DARI GERAKAN INOVASI NASIONAL 2012



WIF-KL 2012

OPPORTUNITIES

CONFERENCES

EXHIBITIONS

SATELLITE EVENTS

NEWS & PRESS RELEASES

FAQs

RESOURCES

Lawatan Panel Penilai



05.11.2012



05.11.2012



Peruntukan / Dana

SELANGOR STATE TREASURY
TINGKAT 2, 8-12
BANGUNAN SULTAN SALAHUDDIN ABDUL AZIZ SHAH
40582 SHAH ALAM
SELANGOR DARUL EHSAN
MALAYSIA

"KEJUJURAN DAN KETEKUNAN"

Rujukan Kami : PVN Sel (A) 333 Jld7 (34)
Tarikh : 23 Zulhijah 1431H
30 November 2010

Pengarah,
Jabatan Kerja Raya Malaysia,
Cawangan Kejuruteraan Elektrik Negeri Selangor,
Tingkat 1, Bangunan SSAAS,
40582 SHAH ALAM.
(u.p. : Enck Ir. Mat Nasir Bin Kari)

Tuan,

KELULUSAN PERUNTUKAN CADANGAN PENAMBAHBAIKAN DAN PENGAUDITAN TENAGA DI BANGUNAN SSAAS, SHAH ALAM SELANGOR DARUL EHSAN

Dengan hormatnya saya diarah merujuk surat tuil bil. () din JKR/ES/2/4/12 bertarikh 26 November 2010 adalah berkaitan.

2. Adalah dimaklumkan bahawa Perbendaharaan Negeri telah meluluskan permohonan tersebut bagi pemasangan penjimatan tenaga elektrik pada sistem motor pam sedia ada di Bangunan Sultan Salahuddin Abdul Aziz Shah (SSAAS) dengan peruntukan berjumlah RM250,000.00 (Ringgit Malaysia : Dua Ratus Lima Puluh Ribu Sahaja).

4. Dengan kelulusan ini, pihak tuan bolehlah mengambil tindakan selanjutnya bertakluk kepada peruntukan sedia ada Jabatan mencukupi dan prosedur kewangan semasa dan lain-lain peraturan yang ditetapkan oleh Kerajaan dipatuhi.

Sekian, terima kasih.

"BERKHIDMAT UNTUK NEGARA"

Saya yang menurut perintah,

(AHMAD MUHAMIN BIN MOHAMED)
Penolong Pegawai Kewangan Negeri (Belanjawan) 3
b.p. Pegawai Kewangan Negeri Selangor

PROSIP/PROK/11.3000

No. Telefon : 03-5544 7000
No. Faks : 03-5510 6235 (PB/PWN),
03-5512 1515 (177-177C)

Malaysia Electricity Supply Industries Trust Account (MESITA) KeTTHA

On-line Application
MESITA
Malaysia Electricity Supply Industries Trust Account

HOME PROJECTS ENQUIRY

Please click on the short-cut menu below to navigate the each category of project details

PROJECT SUMMARY APPLICATION FORM SCHEDULE MEETING REPORTS

Form Application Details

APPLICATION DETAIL FOR FUNDING FROM ELECTRICITY TRUST FUND

I. PROJECT IDENTIFICATION
PROJECT NO. 04-2-15-1990
PROJECT TITLE Energy Efficiency in Bangunan Sultan Salahuddin Abdul Aziz Shah, Shah Alam, Selangor
ORGANISATION Jabatan Kerja Raya (JKR)
KEY WORDS Harmonic/ Capacitor bank/Motor (Water Pump)/Starting Current/Improvement energy
APPLICATION DATE 08/02/2011

II. OBJECTIVES OF THE PROJECT
A. OBJECTIVE(S) OF THE PROJECT
1. To improve energy efficiency in motor operation (Water Pump)
2. To deliver & reduce losses during operation process

B. RESEARCH BACKGROUND OF PROJECT (FOR RESEARCH PROJECTS)
Modification Previous Project

PROJECT STATUS
PROJECT LEADER Datu Abdullah Bin Abd Rahman Ir. Mat Nasir bin Kari Ir. Zulaika Binti Hj. Zakaria

LITERATURE REVIEW SUMMARY
The efficiencies of the current motors (Water Pump, Chiller) are relatively low. It would not be economically viable to replace the operated pumps with higher efficiency. However, it is recommended that in future to emphasize more power factor improvement. Normal Star-Delta coupled with Autotransformer for motor starting will subject the motor to high torque and current surges up to 10 times the full load current. However it is recommended 4 Steps Autotransformer for a starting device to reduce starting current & starting high torque.

RELATED RESEARCH
To achieve energy consumption by improving efficiency of motor pumps. This would lessen mechanical and electrical stress on the motor system and can reduce maintenance and repair cost and extend mo

TYPE OF RESEARCH
RESEARCH METHODOLOGY
Technology Development (Applied Research)
1. Installation Energy Saving Device (ESD) 2. Improvement starting current system by using 5 Steps Autotransformer coupled with capacitor banks parallel operation to reduce starting current & improvement power factor.

III. BENEFITS OF THE PROJECT

KEMENTERIAN TENAGA, TEKNOLOGI HIJAU DAN AIR MALAYSIA
Ministry of Energy, Green Technology and Water, Malaysia
BLOK B4/5, KOMPLEKS KERAJAAN PARCEL E
PUSAT PENTADBIRAN KERAJAAN PERSEKUTUAN
62668 PUTRAJAYA, MALAYSIA

KeTTHA
KEMENTERIAN TENAGA,
TEKNOLOGI HIJAU DAN AIR

Telefon : +603-88836000
Faks : +603-88893712
Laman Web : http://www.kettha.gov.my

Ruj. Kami : KeTTHA: BT(S) 17/1 Jld. 6 (37)

Tarikh : 14 Jun 2012

SEGERA DENGAN FAKS (03-5510 3790)

Ir. Mat Nasir Bin Kari
Jabatan Kerja Raya (JKR)
JKR Selangor
Tingkat 1, Bangunan SSAAS
40582 Shah Alam

Tuan,

PEMBIAYAAN AKAUN AMANAH INDUSTRI BEKALAN ELEKTRIK (AAIBE)

Dengan hormatnya saya merujuk kepada perkara di atas.

2. Sepertimana tuan sedia maklum, mesyuarat Jawatankuasa Akaun Amanah Industri Bekalan Elektrik (AAIBE) Bil. 1/2012 pada 17 Mei 2012 telah meluluskan secara bersetat peruntukan berjumlah RM900,000.00 kepada UTM dan JKR, Selangor bagi melaksanakan "Optimal Capacitor Placement And Sizing with Autotransformer for Energy Saving of Several Government Buildings in Selangor" untuk tempoh 2 tahun. Syarat - syarat adalah seperti berikut :

- Hasil kajian termasuklah cost-benefit analysis, prototype model dan Artificial Intelligence Optimization Technique boleh direplikasikan untuk penjimatan elektrik di bangunan-bangunan kerajaan dan industri.
- AAIBE tidak akan membiayai pemasangan kapasitor dan autotransformer yang ideal di beberapa bangunan kerajaan lain di Selangor. JKR perlu mengusahakan pembiayaan sendiri.
- Program kesedaran kecekapan tenaga yang dilaksanakan perlu menekankan kaedah bagaimana mengubah minda dan sifat manusia untuk menjimatkan elektrik.

3. Sehubungan dengan itu, kerjasama pihak tuan adalah dipohon untuk mengemukakan draft perjanjian proses yang direplikasi di dalam darjah Malaysia sepenuhnya kepada Unit Setia AAIBE dalam tempoh 30 hari dari tarikh penerimaan surat ini untuk tindakan seterusnya.

Sekian, terima kasih.

"BERKHIDMAT UNTUK NEGARA"


Saya yang menurut perintah,

(AHMAD MUHAMIN BIN MOHAMED)
Penolong Pegawai Kewangan Negeri (Belanjawan) 3
b.p. Pegawai Kewangan Negeri Selangor



Peruntukan sebanyak RM 250,000.00 dari Perbendaharaan Negeri Selangor bagi pemasangan Peralatan penjimatan tenaga di Bangunan SSAAS.

Peruntukan dari Akaun Amanah Industri Bekalan Elektrik (AAIBE/MESITA) dengan kolaborasi bersama Universiti Teknologi Mara Malaysia sebanyak RM900.000.00

Kolaborasi JKR-UiTM – Projek Penyelidikan



3. Metodologi Modeling





TEKNOLOGI HIJAU

- Meminimalkan kesan negatif kepada alam sekitar
- Penggunaan tenaga yang cekap dan tiada pembaziran tenaga
- TENAGA LESTARI

Objektif



NEGARA

Kos operasi kerajaan dapat dikurangkan

- Dapat disalurkan ke Program yang berfaedah kepada Rakyat




ORGANISASI


- Penggunaan sumber manusia yang lebih efisien
- *'Delighting the customer Customer'*

Diagram of Research Methodology

**MATLAB Programming :
Artificial Intelligence Based Optimization Technique**



Legend :



- a) Capacitor Sizing and location.
- b) Instruction to execute power flow solution.



Transfer the results of voltage, current, THD, real power , reactive power and power factor.

MATLAB Programming : Artificial Intelligence Based Optimization Technique

The image displays the MATLAB 7.10.0 (R2010a) environment. The main window shows a script titled 'main_coding.m' in the Editor, which implements a Particle Swarm Optimization (PSO) algorithm for a transformer system. The script includes comments in Indonesian and sets various parameters for the PSO and the system model.

```
1 % OPTIMIZATION ALGORITHM FOR J.K.R ELECTRICAL SYSTEM OF TRANSFORMER 1 %
2 clear close all
3 clc
4 %JKR_1 SYSTEM & PSO PARAMETER %
5 JKR_1_sys_pso_param % program that store parameters of the system and PSO
6
7 % USER OPTIONS %
8 compensation_type='three-phase'; % 'three-phase' or 'per-phase'
9
10 max_desired_pf=1; % desired power factor to be achieve - to get the maximum sizing
11 min_desired_pf=0.0;
12
13 cap_range =1e3*[10:10:200]; % capacitor rance [smallest value: incremental value : largests value]
14 cap_step = 10e3; % incremental value- to get the number of capacitor step
15
16 chosen_risor =[5,6,7,8,9,10]; % choose from risor 1 to 10
17
18 % PARTICLE SWARM OPTIMIZATION PARAMETER %
19 delta=rand; % [CAN BE ADJUST]- vary from 0 to 1 - constant to control max/min speed of the particles
20 pso.psoMethod = 'constriction'; % [SELECT] choose either 'basic' OR 'inertia' OR 'constriction' **
21 pso.maxIter = 500; % [CAN BE ADJUST] maximum no of iteration
22 pso.noParticles = 3; % [CAN BE ADJUST] no of particles that contain sample solution ***
23
24
25
```

The Command Window shows the output of the script, including a table of initial states and a warning message about the simulation step size.

	0	0	0	0	120000	80000	40000	80000	0	100000
0	0	0	0	0	120000	80000	40000	80000	0	100000
0	0	0	0	0	120000	80000	40000	80000	0	100000

Current plot held

iter =

37

The electrical initial states of your model are forced to steady state by the powergui block.

Warning: Using a default value of 0.006 for maximum step size. The simulation step size will be equal to or less than this value. You can disable this diagnostic by setting 'Automatic solver parameter selection' diagnostic to 'none' in the Diagnostics page of the configuration parameters dialog

> In [main_coding at 154](#)





The electrical initial states of your model are forced to steady state by the powergui block.

Warning: Using a default value of 0.006 for maximum step size. The simulation step size will be equal to or less than this value. You can disable this diagnostic by setting 'Automatic solver parameter selection' diagnostic to 'none' in the Diagnostics page of the configuration parameters dialog


> In [main_coding at 154](#)

Program Pengumpulan Data Berperingkat – Data Logger







Simulink : IEEE13 Bus Unsymmetrical Electrical Distribution System



Five (5) Sections of Electrical Distribution System in SSAAS



Section Three (3) of Electrical Distribution System in SSAAS



Electrical Components Installed in Section 3 of Electrical Distribution System in SSAAS

Number of risers		10 risers			
Type of cable used as a riser		4x1C 240mm ²	4x1C 400mm ²	4x1C 300mm ²	4x1C 35mm ²
Impedance of cable	R	0.091 Ω	0.059 Ω	0.037 Ω	0.627 Ω
	XR	0.09 Ω	0.088 Ω	0.086 Ω	0.114 Ω
Incoming Transformer Rating		11 kV / 433 V, 1600 kVA Δ/Y Connection			
Capacitor bank sizing		50 kVAR x 6 banks = 300 kVAR			




Data Sheet of Cables used as the Riser Installed in Section 3 of Electrical Distribution System in SSAAS


4 CORE COPPER PVC ARMoured & UNARMoured POWER CABLES

No. of cores & cross sectional area	Min. No. of Wires	Thickness of PVC insulation (Nom.)	Min. Thickness of PVC inner sheath mm	ARMURED								UNARMURED			Max. D.C. Resistance at 20	Max. A.C. Resistance at 70	Approx. Reactance at 50 Hz	Approx. Capacitance	CURRENT RATINGS		
				Nominal Dimensions of Armour		Min. Thickness of PVC Outer Sheath		Overall Diameter (Approx.)		Approx. Net Wt. of Cable		Nom. Thickness of Outer Sheath mm	Overall Diameter (Approx) mm	Net Wt. of Cable (Approx) Kg/Km					Direct Ground Amps	In Duct Amps	In Air Amps
				Strip mm	Wire mm	Strip mm	Wire mm	Strip mm	Wire mm	Strip (Kg/Km)	Wire (Kg/Km)										
4CX 35	6	1.2	0.3	4x0.8	1.60	1.40	1.56	25.9	27.8	1955	2254	2.00	26.10	1744	0.524	0.62	0.097	0.98	120	110	99
4CX 240	34	2.2	0.6	4x0.8	2.50	2.36	2.36	56.7	60.1	11008	12415	3.00	57.20	10557	0.0754	0.091	0.087	1.34	345	355	295
4CX 300	34	2.4	0.7	4x0.8	3.15	2.52	2.68	62.9	68.0	13610	15877	3.40	64.10	13218	0.0601	0.073	0.086	1.41	385	400	335
4CX 400	53	2.6	0.7	4x0.8	3.15	2.84	2.84	70.6	75.3	17213	19697	3.60	71.50	16729	0.0470	0.059	0.086	1.45	425	455	360


Active Power within the range of 103 kW and 97 kW at the riser of Main Switchboard Aircond



Voltage magnitude within the range of 244 V and 238 V at the riser of Main Switchboard Aircond



Delta-Connected Capacitors Considered in the Optimization: Section Three (3) of Electrical Distribution System in SSAAS



Delta-Connected Capacitors Considered in the Optimization: Section Three (3) of Electrical Distribution System in SSAAS


Delta connected	Wye connected
- Friendly to the electrical environment. - Provides capacitance to each phase and also provides no voltage unbalances (harmonics).	- It is not appropriate application - It has the potential to cause a catastrophic failure not only the capacitor but to the motor. - The main reason for this is because they are ungrounded and thus can present a potential difference on each phase of the capacitor which in turn contributes to the over-all deterioration of the capacitor and the attached motor.
If a capacitor cell should fail for any reason in one phase, therefore a closed delta will become into an open delta configuration. In this instance the voltages on each phase stays the same. Failure of a capacitor cell would only mean a drop in the kVAR on the circuit. In other words, a 30kVAR delta connected three phase capacitor with a failed cell would provide 20kVAR to the electrical system instead of 30kVAR.	The failure of any one cell of a Wye connected capacitor presents an unbalanced load to the motor. This will effectively destroy the motor due to unbalanced voltage, temperatures.



Delta-Connected Capacitors Considered in the Optimization: Section Three (3) of Electrical Distribution System in SSAAS

Delta connected	Wye connected
• Unprotected delta connected capacitors usually used for Power Factor correction. In fact, the unbalance protection required for this type of application is cheaper.	• Unprotected Wye connected capacitors should not be used for Power Factor correction for similar reasons. In fact, the unbalance protection required for this type of application is more costly than the capacitors themselves and therefore not generally included with Wye connected capacitors.
• Delta connected capacitors unlike the Wye connected capacitors are able to circulate harmonics currents within the delta circuit and by doing so help to reduce the harmonics on the electrical system.	• Wye connected capacitors also do not circulate harmonics and thus are much more vulnerable to failure due to harmonics

4. Hasil Kajian – Sistem Pengagihan



Analysis for the Results of Section Three (3) of Electrical Distribution System In SSAAS

Objective function	Before Optimization (Base Case)	After Optimization		
		1 st Run	2 nd Run	3 rd Run
Total Energy Consumption (kWh)	689.959 kWh	430.97 kWh	402.81 kWh	378.13 kWh
Total Energy Reduction/Saving		258.989 kWh	287.149 kWh	311.829 kWh
Percentage of Total Energy Reduction/Saving (%)		37.5%	41.6%	45.2%
Electricity Bil per month	RM 53,816.00	RM 33,615.00	RM 31,419.00	RM 29,494.00
Savings of Electricity Bil per month		RM 20,783.00	RM 23,043.00	RM 25,024.00
Percentage of Savings for Electricity Bil per month		37.5%	41.6%	45.2%
Constraints				
Voltage	0.9 p.u. < V < 1.1 p.u.			
THD Voltage	THDV < 5%			
Lowest Power Factor	0.71 p.f.	0.9155 p.f.	0.9150 p.f.	0.9151 p.f.



Electricity Bil Calculation

- Losses reduction is:

$$\Delta P = \frac{6795 - 3978}{6795} * 100 = 41.4\%$$

- Annual saved energy is:

$$\Delta S = \frac{\Delta P * \text{hours / month} * 12 \text{ months}}{1000} = \frac{2817 * 600 * 12}{1000} = 20282 \text{ kWh}$$

Electricity Tariff



[Home](#) | [CSR](#) | [Careers](#) | [Scholarships](#) | [FAQs](#) | [Contact Us](#)

Tenaga (Bursa Malaysia) RM 9.09

[Residential Customers](#)

[Business Customers](#)

[Investors](#)

[Suppliers](#)

[About TNB](#)



Business

▼ For Commercial

[Pricing & Tariff](#)

[CARE Program](#)

[Maximum Demand](#)

[Bulk Payment System](#)

[Bulk Supply Interconnection
Guideline](#)

► For Industrial

► For Housing Developers & Electrical Contractors

► Discounts, Rebates & Offers

► Charges and Penalties

[Energy Savings at Work](#)

[Power Quality](#)

[Tenaga Link](#)

[Malaysian Grid Code](#)

[Meter Replacement
Programme](#)

[Home](#) > [Business](#) > [For Commercial](#) > [Pricing & Tariff](#)

Pricing & Tariff



[Print this page](#)

	TARIFF CATEGORY	UNIT	RATES
1.	Tariff B - Low Voltage Commercial Tariff		
	For Overall Monthly Consumption Between 0-200 kWh/month		
	For all kWh	sen/kWh	39.3
	<i>The minimum monthly charge is RM7.20</i>		
	For Overall Monthly Consumption More Than 200 kWh/month		
	For all kWh (From 1kWh onwards)	sen/kWh	43.0
	<i>The minimum monthly charge is RM7.20</i>		
2.	Tariff C1 - Medium Voltage General Commercial Tariff		
	For each kilowatt of maximum demand per month	RM/kW	25.9
	For all kWh	sen/kWh	31.2
	<i>The minimum monthly charge is RM600.00</i>		
3.	Tariff C2 - Medium Voltage Peak/Off-Peak Commercial Tariff		
	For each kilowatt of maximum demand per month during the peak period	RM/kW	38.60
	For all kWh during the peak period	sen/kWh	31.2
	For all kWh during the off-peak period	sen/kWh	19.2
	<i>The minimum monthly charge is RM600.00</i>		

Conclusions

The implementation of the proposed strategy method is to mitigate starting current and reduce the maximum demand. Improving energy efficiency.

This is the core of sustainability energy in the hope that future generations can appreciate complex systems and energy usage.

This will enable cost saving and profit increase and may prove to be deciding factor providing the competitive edge to the final product.



TERIMA KASIH

Di atas perhatian anda.....



Energy is not free
but learning to save it...

