

# **POWER QUALITY STUDY**

## **MOULDED CASED CIRCUIT BREAKER (MCCB) TRIPPING AT COMPUTER LABORATORY SUB-SWITCHBOARD**



Politeknik Seberang Perai P.Pinang

# POWER QUALITY TEAM

Power Quality Team  
Caw. Kejuruteraan Elektrik  
JKR Malaysia



Power Quality Unit  
Universiti Teknologi MARA  
Pulau Pinang



Hj. Nizar Othman  
Noor Ashikin Md Tamimi  
Hamzah Ismail  
Mohd Azlan Othman  
Elyas Nordin  
Shaiful Izzuddin Mohamad

Assoc. Prof. Mohd Zaki Abdullah  
Assoc. Prof. Rusnani Ariffin  
Sa'adiah Mohd Said  
Wan Salha Saidon  
Mohamad Sarih Daud


# INTRODUCTION



**PROBLEM  
STATEMENT**

**Moulded Case Circuit Breaker  
(MCCB) tripping at the Sub-  
Switchboard (SSB 'CL') for  
Computer Laboratory Block**

# INTRODUCTION




# OBJECTIVE

To identify the **causes** of the MCCB tripping at the Sub-Switchboard (SSB 'CL')



# WORKFLOW PROCESS

- a. Briefing
- b. Site Investigation
- c. Power Quality Monitoring
- d. Data Analysis
- e. Joint Venture Report
- f. Presentation to PSP



a

b

c

d

e

f




# INVESTIGATION PROCEDURE

- **Visual inspection** of installation as per wiring regulation requirements.
- A measurement was done using power quality **monitoring equipment Fluke 1750** at the incoming of MCCB at SSB 'CL'.
- The power monitoring was recorded from **21<sup>st</sup> until 31<sup>st</sup> October 2013** (with a sampling rate of 10ms).



# A simplified single line diagram for the SSB 'CL'



# FINDINGS

During the measurement period, there was **no tripping incident** but there were **events on voltage swells** (overvoltages) which recorded 5,337 times.




# FINDINGS

- Voltage Summary**

|         | 10 minutes trend data average RMS |                  |                  | Detail view data average RMS |                  |                  |
|---------|-----------------------------------|------------------|------------------|------------------------------|------------------|------------------|
| Phase   | V <sub>L1N</sub>                  | V <sub>L2N</sub> | V <sub>L3N</sub> | V <sub>L1N</sub>             | V <sub>L2N</sub> | V <sub>L3N</sub> |
| Voltage | 256.50V                           | 257.95V          | 257.83V          | 258.14V                      | 259.91V          | 259.55V          |
|         | (+11.52%)*                        | (+12.15%)*       | (+12.10%)*       | (+12.23%)*                   | (+13.00%)*       | (+12.85%)*       |

*\*These average RMS voltages are exceed +10% limit of the nominal voltage.*


Figure below shows the voltage fluctuation is 21V (9.3%) are considered high (above 6% of nominal voltage, i.e.>13.8V)



# FINDINGS

- Voltage Summary**


Recorded data shows that, when the current increase and the voltage drop significantly (or vice versa) shows that the electrical distribution system for SSB'CL' has high system impedance.



# FINDINGS

- Current Summary


|         | 10 minutes trend data average RMS |         |         | Detail view data average RMS |         |         |
|---------|-----------------------------------|---------|---------|------------------------------|---------|---------|
| Phase   | L1                                | L2      | L3      | L1                           | L2      | L3      |
| Current | 216.97A                           | 188.08A | 205.09A | 259.13A                      | 220.55A | 239.77A |



# FINDINGS

- Current Summary

| Data                              | Unbalance Neutral Current, $I_N$ | Indicator                                          | Effect to the system          |
|-----------------------------------|----------------------------------|----------------------------------------------------|-------------------------------|
| 10 minutes trend data average RMS | 55.12 A                          | > the earth fault relay pick up current (i.e 50 A) | nuisance tripping to the MCCB |
| Maximum current unbalance (%)     | 23.41%                           |                                                    |                               |



# FINDINGS

- **Harmonic Summary**

The value of Voltage Total Harmonic Distortion ( $V_{THD}$ ) and Current Total Harmonic Distortion ( $I_{THD}$ ) for SSB 'CL' :

| Phase                      | L1N   | L2N   | L3N   | Indicator                                                                                                     |
|----------------------------|-------|-------|-------|---------------------------------------------------------------------------------------------------------------|
| Average $V_{THD}$<br>(Max) | 1.22% | 1.55% | 1.20% | The values of $V_{THD}$ <u>are acceptable and within the limit</u> (< 8 % based on IEC 61000-2-2)             |
| Phase                      | L1    | L2    | L3    | Indicator                                                                                                     |
| Average $I_{THD}$<br>(Min) | 3.45% | 5.29% | 2.39% | The values of $I_{THD}$ <u>are low and do not contribute</u> to the distortion of the supply voltage waveform |

**The low  $V_{THD}$  and  $I_{THD}$  that are generated by the loads connected to distribution boards are not related to the tripping of MCCB.**



# FINDINGS

## • Neutral to Ground Voltage, $V_{NG}$

| Data                              | $V_{NG}$         | Indicator                                                                                                        | Caused by                                                                                                                                                                                     | Effect to the system                                                                                                                                                         |
|-----------------------------------|------------------|------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 10 minutes trend data average RMS | 16.65V           | <i>high levels of <math>V_{NG}</math></i>                                                                        | <ol style="list-style-type: none"> <li>1. indicates a <u>loose/corrode connection</u> at the ground electrode</li> <li>2. the <u>volt drop along the resistance</u> of the neutral</li> </ol> | <ol style="list-style-type: none"> <li>1. contributes to the <u>power quality problem</u></li> <li>2. some of the <u>sensitive loads are disrupted or damaged</u></li> </ol> |
| Detail view data average RMS      | 87.47V (impulse) | <i>The magnitude of <math>V_{NG}</math> is <b>high</b> (values above 4.3% (&gt; 10V) of the nominal voltage)</i> | Neutral to ground impulses indicate that there are <u>wiring errors</u> in the electrical wiring installation (intermittent single line-to-ground fault)                                      | Neutral to ground impulses can result in <u>equipment damage</u> over time and also can cause <u>nuisance tripping</u> of Residual Current Circuit Breaker (RCCB)            |



# FINDINGS

- Neutral to Ground Voltage

*The neutral to ground event recorded :*


| #     | Date/Time                   | Type  | Duration (Days - Hrs:Min:Sec) | % of Nominal | Absolute | Triggered Phase |
|-------|-----------------------------|-------|-------------------------------|--------------|----------|-----------------|
| 1,707 | 24/10/2013 09:44:13.183.227 | Swell | 0 - 00:00:00.039945700        | 37.94%       | 87.267 V | NG              |
| 30    | 21/10/2013 19:06:43.393.282 | Swell | 0 - 00:00:00.050085300        | 37.71%       | 86.738 V | NG              |
| 2,199 | 25/10/2013 21:27:36.636.293 | Swell | 0 - 00:00:00.049950100        | 33.09%       | 76.098 V | NG              |
| 28    | 21/10/2013 19:06:42.772.153 | Swell | 0 - 00:00:00.050091000        | 27.90%       | 64.174 V | NG              |
| 1,294 | 23/10/2013 13:20:03.005.678 | Swell | 0 - 08:31:49.181644700        | 27.30%       | 62.779 V | NG              |
| 2,244 | 25/10/2013 21:36:32.656.549 | Swell | 0 - 00:00:00.059933600        | 26.05%       | 59.916 V | NG              |
| 2,196 | 25/10/2013 21:27:01.410.350 | Swell | 0 - 00:00:00.039888400        | 25.89%       | 59.558 V | NG              |
| 812   | 22/10/2013 19:13:07.753.516 | Swell | 0 - 00:00:00.040034300        | 25.49%       | 58.636 V | NG              |
| 2,194 | 25/10/2013 21:26:56.834.019 | Swell | 0 - 00:00:00.039966300        | 24.43%       | 56.187 V | NG              |
| 2,235 | 25/10/2013 21:34:06.588.812 | Swell | 0 - 00:00:00.040027100        | 23.03%       | 52.975 V | NG              |
| 2,195 | 25/10/2013 21:26:58.962.196 | Swell | 0 - 00:00:00.039959800        | 22.87%       | 52.594 V | NG              |
| 2,198 | 25/10/2013 21:27:15.579.415 | Swell | 0 - 00:00:00.039965800        | 22.69%       | 52.191 V | NG              |
| 2,207 | 25/10/2013 21:28:48.591.284 | Swell | 0 - 00:00:00.039974100        | 21.65%       | 49.798 V | NG              |
| 2,242 | 25/10/2013 21:35:52.533.829 | Swell | 0 - 00:00:00.039952400        | 21.61%       | 49.696 V | NG              |
| 2,239 | 25/10/2013 21:34:45.050.995 | Swell | 0 - 00:00:00.039946400        | 21.03%       | 48.369 V | NG              |

*The neutral to ground impulses :*



# FINDINGS

- Event Summary



Plot of events on a CBEMA voltage tolerance curve

# CONCLUSION

- The summary of events at SSB 'CL':

|   | Event recorded                                                         | Caused by                                                                                                                         | Effect to the system                                             |
|---|------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------|
| 1 | <b>Voltage fluctuation</b> > 6% (i.e >13.8V) of nominal voltage        | <u>High system impedance</u> and exaggerates the effect of current increases                                                      | Voltage swells                                                   |
| 2 | <b>Significant Voltage drop &amp; Current increase</b> (or vice versa) | <u>Loose or defective wiring</u> , such as insufficiently tightened screws connection on power conductors or corroded connections | Electrical distribution system SSB'CL' has high system impedance |
| 3 | <b>Unbalance Neutral Current, <math>I_N</math></b>                     | $I_N >$ the earth fault relay pick up current i.e 50 A (for this SSB 'CL')                                                        | Nuisance tripping to the MCCB                                    |


# CONCLUSION

|   | Event recorded                                                                            | Caused by                                                                                                                                                                                               | Effect to the system                                                                                                                                           |
|---|-------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 4 | <b>High Neutral to Ground Voltage,</b><br>$V_{NG} (> 10V \text{ of the nominal voltage})$ | <ol style="list-style-type: none"> <li>1. indicates a <u>loose/corrode connection</u> at the ground electrode</li> <li>2. caused by the <u>volt drop</u> along the resistance of the neutral</li> </ol> | <ol style="list-style-type: none"> <li>1. contributes to the power quality problem</li> <li>2. some of the sensitive loads are disrupted or damaged</li> </ol> |
| 5 | <b>Neutral to ground impulse</b>                                                          | Neutral to ground impulses indicate that there are <u>wiring errors</u> in the electrical wiring installation (intermittent single line-to-ground fault)                                                | Neutral to ground impulses can result in equipment damage over time and also can cause nuisance tripping of Residual Current Circuit Breaker (RCCB)            |
| 6 | <b>Overvoltages</b>                                                                       | the insulation of the equipment                                                                                                                                                                         | shorten the lifespan of the equipment                                                                                                                          |

# Recommendation


## ■ Improvement of Electrical Wiring Installation

1. Check the wiring installation of the electrical system and correct all the wiring errors such as improper neutral-to-ground bond, intermittent single line-to-ground fault and improper cable joint.
2. Check for loose neutral connections.
3. Inspect the wiring for other equipment, light fittings etc. for loose joints and terminations.



# Recommendation

4. To mitigate high neutral-to-ground voltage, it is recommended to install an isolation transformer connected as separately derived system. The transformer should be placed near to the load.



To separate dedicated nonlinear loads, linear loads and an isolation transformer is used for sensitive equipment

# Recommendation

## ■ Improvement of Grounding System

1. Connection between grounding conductor to the ground electrode at the transformer and main switchboard (MSB) should be by exothermic weld, not clamps that can loosen over time.



# Recommendation

2. Only one ground electrode system at the MSB should be implemented. A separate ground electrode should never be used to ground any piece of electrical equipment. Separate ground electrodes always create two ground references at different potentials, which in turn cause a “ground loop” current to circulate in an attempt to equalize those potentials. In the case of lightning strikes, surge currents travelling to ground at different earth potentials will create hazardous potential differences.



# Recommendation

- **Immediate Action to be taken**
  1. Redistribute final circuit loads to improve balance of the three phases. The maximum unbalance current should be below the earth fault relay pick up current.
  2. Reduce the supply voltage to the nominal value by changing the position of the tap-changer of the transformer.



# Impact to Politeknik Administration

- **The report will be send to the polytechnic for their action:**
- Inform maintenance department to identify repair work to carried out
- Get estimation for the maintenance allocation



**...THANK YOU**



Politeknik Seberang Perai P.Pinang