

SECTION 5.7 SPECIFICATION FOR COMPREHENSIVE SERVICE AND MAINTENANCE OF THE TOTAL FLOODING FIRE EXTINGUISHING SYSTEM AND ANCILLARY EQUIPMENT

1 <u>GENERAL</u>

The work covered by this Specification is for the supply of all materials, appliances, labour and necessary incidentals for the service and maintenance of the Fire Fighting System and Ancillary Equipment.

All work to be performed under this Specification shall be in accordance with the commercial practice, and must be in strict accordance with this Specification.

2 WORKMANSHIP AND MATERIALS

The work described in this Specification shall be performed by workmen skilled in the service, maintenance and repair of Fire Fighting System and Ancillary Equipment of all types, and shall be executed in accordance with the best commercial practice.

All materials to be supplied in connection with work under this Specification shall be new and unused, and shall generally be of the best quality as regard manufacture and performance.

3 <u>SUPERVISION</u>

The Contractor shall have a Foreman in charge of the service, maintenance and repair work to be carried out under this Specification. This Foreman must be thoroughly competent in supervising the service, maintenance and repair of the Fire Fighting System and Ancillary Equipment of all types and shall be in the direct employ of the Contractor, and acceptable to the Superintending Officer.

The Contractor shall have in his direct employ, workmen who are especially skilled in the service, maintenance and repair of Total Flooding Fire Extinguishing System and Ancillary Equipment of all types.

4 <u>SCOPE OF WORK</u>

All machinery and equipment comprising the complete Total Flooding Fire Extinguishing System and Ancillary Equipment shall be serviced and maintained.

The service and maintenance of the complete Total Flooding Fire Extinguishing System and Ancillary Equipment shall be in strict accordance with the Servicing and Maintenance Schedule as set out in clause 5.10 below.

The Contractor shall advise the Superintending Officer of any defects in any part or parts of the complete Total Flooding Fire Extinguishing System and Ancillary Equipment observed during routine inspection and service, and shall repair such defects if required to do so by the Superintending Officer.

The Contractor shall also provide emergency repair service during normal working hours and also during overtime hours if required to do so by the Superintending Officer.



5 CONSUMABLE MATERIALS

The Fire Fighting Contractor shall supply the following consumable materials as and when required:-

1. All cotton waste, soap detergent and other cleaning materials required for cleaning purposes.

The costs of these consumable materials shall not be charged for separately by the Contractor, but shall be included in the fixed monthly rate quoted by the Contractor for the Service and Maintenance of the Complete Total Flooding Fire Extinguishing System and Ancillary Equipment.

6 <u>REPAIRS</u>

The Contractor shall repair defects in the complete Total Flooding Fire Extinguishing System and Ancillary Equipment on the instructions of the Superintending Officer. The costs of such repair shall be deem to be included in the fixed monthly rate quoted by the Contractor for the Service and Maintenance of the complete Total Flooding Fire Extinguishing System and Ancillary Equipment but shall be charged for separately by the Contractor.

All repairs on the complete Total Flooding Fire Extinguishing System and Ancillary Equipment shall be guaranteed by the Contractor against defects in workmanship and materials for a period of one year to take effect from date of completion of repairs. During the guarantee period the Contractor shall rectify defects in repairs carried out by him with no additional charge to the Government.

7 SERVICE AND MAINTENANCE RECORDS

- 1. The Contractor shall provide a service and maintenance record book for the complete Total Flooding Fire Extinguishing System and Ancillary Equipment being serviced and maintained by him. This record book shall be kept in the plant room of the Total Flooding Fire Extinguishing System and Ancillary Equipment being serviced and maintained, and brief details of all service, maintenance and repairs carried out on the complete Total Flooding Fire Extinguishing System and Ancillary Equipment shall be entered by the Contractor into this book for checking purposes. The address and telephone number of the Contractor's service station shall also be entered into this record book to facilitate emergency service calls.
- 2. The Contractor shall also keep an accurate detailed record in duplicate of all service, maintenance and repair work carried out by him on the complete Total Flooding Fire Extinguishing System and Ancillary Equipment. This record shall be in the form of a Maintenance/Repair Sheet, and shall be countersigned by the Superintending Officer each time the Total Flooding Fire Extinguishing System and Ancillary Equipment is attended to by the Contractor.

8 RATES FOR SERVICE AND MAINTENANCE

The rates for the Service and Maintenance of the complete Total Flooding Fire Extinguishing System and Ancillary Equipment shall be as shown in the Schedule



of Prices for this Contract.

These rates shall be quoted for by the Contractor at the time he submits his tender, and shall hold good for the period of **THREE years** commencing from the end of the warranty period. The Contractor may be required to enter into a contract for the above period with the Government on the Standard Form of Contract for Service and Maintenance of Total Flooding Fire Extinguishing System and Ancillary Equipment (a copy of this Standard Form may be inspected at the Office of the Pengarah Kanan, Cawangan Kejuruteraan Mekanikal, Ibu Pejabat J.K.R. Malaysia, Kuala Lumpur.

9 PAYMENTS

Payments shall be made in accordance with Clause 24 of the Conditions Of Contract of Section 1, General Specification, but bills presented for payments must be accompanied by a full statement and substantiated by one copy of the individual maintenance/repair records required under paragraph 7(2) of this specification.

10 SERVICING AND MAINTENANCE SCHEDULES

The Contractor shall inspect and service the machinery and equipment comprising the complete Total Flooding Fire Extinguishing System and Ancillary Equipment at the above premises periodically as scheduled in the check list except where otherwise directed by the Superintending Officer.

The check list is in no way exhaustive and shall not in any way relieve the Contractor from executing any other work necessary to ensure the efficient functioning of the Total Flooding Fire Extinguishing System and Ancillary Equipment.

The Contractor shall report in writing to the Superintending Officer any defect/s observed in any part or parts of the complete Total Flooding Fire Extinguishing System and Ancillary Equipment. The report shall state the cause/s of the defect/s observed, and shall include an estimate of the cost of repairs required.

| | | Frequency | | | | |
|-----|---|----------------|------------------|------------------|---------------|--|
| No. | ltem | Every Month | Every 3 Month | Every 6 Month | Every Year | |
| 1 | CONTROL PANEL | | | | | |
| а | Inspect the condition of components, resistors wires, zone cards and etc. Repair or replace as necessary. | х | | | | |
| b | Check and test AC & DC power supply and conduct current voltage continuity and earthing test. | | х | | | |
| С | Inspect the condition of the battery and battery charger. Repair or replace as necessary. | | Х | | | |



| No. | Item | Frequency | | | | |
|-----|---|----------------|------------------|------------------|---------------|--|
| | | Every Month | Every 3 Month | Every 6 Month | Every Year | |
| d | Inspect and renew electric fuses, LED, reset button, ammeter, voltmeter and etc. as necessary. | | x | | | |
| е | Inspect and check all cable and wiring connections. | | х | | | |
| 2 | DEVICES | | | | | |
| а | Check all wiring and accessories (manual call point, audible & visual alarms, detector, piping conduit and etc.). | х | | | | |
| b | Check all the detectors and ensure they are free from obstruction, dust, dirt and cobwebs. Clean or replace as necessary. | х | | | | |
| 3 | SYSTEM EQUIPMENTS | | | | | |
| а | Inspect the condition of the fittings and connection as necessary (container, discharge nozzle, fire curtain and etc.). | | x | | | |
| b | Inspect the condition and operation of the manual key switch/pull handle. Repair or replace as necessary. | | x | | | |
| С | Inspect and test the correct operation of the bell and warning light. Repair or replace as necessary. | | х | | | |
| 4 | SIMULATION TEST | | | | | |
| а | Conduct a complete system simulation (without discharging the gas). This includes the testing of all detectors, ensuring the fire curtain working properly, the correct sequence of operation of the bell, warning light and gas discharge time. | Х | | | | |
| 5 | PAINTING | | | | | |
| а | Check overall painting and repaint if necessary. | | | Х | | |



11 <u>SCHEDULE OF RATES FOR THE COMPREHENSIVE SERVICE AND</u> <u>MAINTENANCE</u>

The tenderer is to note that the cost quoted for this shall not be included in the tender price but quoted separately in the table below and it will be binding in the event that the Government decides to accept them immediately after the guarantee period.

These rates should not be subjected to variation for the period of 3 years after the free maintenance period.

The tenderer shall quote the rate in Section 8.5

------ END OF SECTION 5.7 ------