

Portable Fire Extinguishers

- a. Obtain Bomba certification upon expiry date.
- b. Inspect any missing, damaged or deteriorated parts
 - on the cylinder,
 - pressure gauge,
 - hose connector,
 - discharge valve,

- handle,
- cylinder safety pin,
- seal and cylinder holder.
- Repair / replace as necessary.
- c. Inspect fire extinguisher cabinet. Repair / replace as necessary.
- d. Inspect the condition of the content. Refill / Replace as necessary.

Painting

- a. Inspect painting, ensure the system (equipment, control panel and piping) are painted with anti rust and coat with red gloss paint.